


NOTES:

- ① BROOM FINISH PERPENDICULAR TO THE DIRECTION OF PEDESTRIAN TRAVEL
- ② FULL DEPTH EXPANSION JOINT
- ③ NO LIP AT GUTTER LINE (NOT TO EXCEED 1/2").
- 4. CURB RAMPS SHALL BE ISOLATED BY EXPANSION JOINT MATERIAL ON ALL SIDES
- ⑤ 3/4" RADIUS DUMMY JOINT
- 6. CATCH BASINS & INLETS SHALL BE INSTALLED A MINIMUM OF 12" FROM THE BASE OF CURB RAMP
- 7. DETECTABLE WARNING PATTERN (TRUNCATED DOMES) SHALL BE FLUSH WITH RAMP TEXTURE +/- NO LANDING. GREATER THAN 1/4".
- ⑧ SEE STND DWG 318 FOR DETECTABLE WARNING PATTERN (TRUNCATED DOMES)
- 9. SEE STND DWGS 315 & 316 FOR SURFACE WATER REQUIREMENTS.
- 10. NO LAMPBLACK SHALL BE PLACED IN CURB RAMPS.



Public Works
Planning
and
Development
Services



Curb Ramp: Type C

320

NOT TO SCALE

Revision Date
December 2006