


NOTES:

- SEE WSDOT/APWA 9-03.12[4]
- IF ROCKERY OR RETAINING WALL IS BEHIND ROLLED CURB, FACE OF ROCKERY OR RETAINING WALL MUST BE A MIN. OF 10' FROM TRAVELED WAY.
- (3) A HANDRAIL, PER STND DWG 324, IS REQUIRED WHEN ROCKERY HEIGHT IS 3' OR GREATER. THE USAGE OF A CHAIN LINK FENCE, PER STND DWG 327, MAY BE APPROVED BY PUBLIC WORKS DIRECTOR OR DESIGNEE.
- (4) BACK OF SIDEWALK SHALL BE A MINIMUM OF 8' FROM FACE OF CURB
- 5. ALL ROCKERIES OVER 4' IN HEIGHT ON PUBLIC OR PRIVATE PROPERTY SHALL HAVE A DETAILED, SIGNED, AND STAMPED DRAWING BY AN ENGINEER.



Public Works Planning

and Development Services



Rock Facing -Cut Section

501

NOT TO SCALE

Revision Date December 2006