



NOTE:

1. MANHOLES SHALL BE CONSTRUCTED IN ACCORDANCE WITH AASHTO M199 UNLESS OTHERWISE SHOWN ON PLANS OR NOTED IN THE WSDOT/APWA STANDARD SPECIFICATIONS.
2. HANDHOLDS IN ADJUSTMENT SECTION SHALL HAVE 3" MIN CLEARANCE. STEPS IN MANHOLE SHALL HAVE 6" MIN CLEARANCE. SEE STND DWG 716, "MANHOLE DETAILS."
3. MANHOLE RINGS & COVERS SHALL BE IN ACCORDANCE WITH THE SURFACE WATER DESIGN MANUAL & MEET THE STRENGTH OF FEDERAL SPECIFICATION RR-F-621D. MATING SURFACES SHALL BE FINISHED TO ASSURE NON-ROCKING FIT WITH ANY COVER POSITION.
4. ALL PRECAST CONCRETE SHALL BE WSDOT CLASS 4000psi.
5. FOR DETAILS SHOWING GRADE RING, LADDER, STEPS, HANDHOLDS, & TOP SLABS, SEE STND DWG 716, "MANHOLE DETAILS."
6. NOT FOR USE IN TRAFFIC BEARING AREAS.

 <p>CITY OF SHORELINE</p>	<p>Public Works Planning and Development Services</p>		<h1 style="margin: 0;">Manhole Type 4</h1>	<h1 style="margin: 0;">715</h1>
				<p>NOT TO SCALE</p>
				<p>Revision Date December 2006</p>